

Dimock Round 3 Data

Sample #	Analyte	Sample Date	Result	Trigger Level	EPA Primary MCL	EPA Secondary MCL	DEP Primary MCL	DEP Secondary MCL
HW08a_R3	Manganese	03-Jul-12	1170 ug/L	320 ug/L		50 ug/L		50 ug/L
HW08a-F_R3	Manganese	03-Jul-12	1150 ug/L	320 ug/L		50 ug/L		50 ug/L
HW08az_R3	Manganese	03-Jul-12	1150 ug/L	320 ug/L		50 ug/L		50 ug/L
HW08az-F_R3	Manganese	03-Jul-12	1160 ug/L	320 ug/L		50 ug/L		50 ug/L
HW08a-P_R3	Manganese	03-Jul-12	176 ug/L	320 ug/L		50 ug/L		50 ug/L
HW08a-PF_R3	Manganese	03-Jul-12	132 ug/L	320 ug/L		50 ug/L		50 ug/L
HW08b-P_R3	Manganese	03-Jul-12	1070 ug/L	320 ug/L		50 ug/L		50 ug/L
HW08b-PF_R3	Manganese	03-Jul-12	1030 ug/L	320 ug/L		50 ug/L		50 ug/L

Sample Number – Code that is used to identify the particular sample. See additional information below:

HW## – Identifies the sample location and indicates that it was collected at well head or closest point to the well head.

F – Indicates that the sample was filtered following collection. The purpose of filtering the sample is to remove any particulates in order to find what metals are actually dissolved in the water sample.

Z – Identifies a duplicate sample. Duplicate samples are collected for every ten samples collected to test the reproducibility of sampling and analytical procedures.

P – Indicates that the sample was collected at the kitchen tap. In some cases this may be following any treatment that the residence may have.

_R3 – Designated the third round of sampling at the wellhead and first round of sampling at the kitchen tap for this particular sampling location.

Analyte – General term for a substance in the sample. The lab does testing to find specific analytes, or substance in the water sample. The report lists each analyte that the lab tested for and what amounts were found.

Result and Units – identifies the actual result for the particular analyte and the measurement used for the particular type of sample. The results may include the following units for the various water sample analyses:

µg /L – Micrograms per liter (abbreviated as µg /L) measurements of the mass of the substance per liter of water. This measurement is commonly known as parts per billion or ppb. Drinking water results are usually reported in µg /L.

Trigger Level – established for this project, the trigger levels are based on risk-based screening levels and/or standards for public water supplies. A yellow highlighted result represents an analytical result greater than the established trigger level. Results exceeding a trigger level are

Dimock Round 3 Data

EPA Primary MCLs – the primary maximum contaminant levels (MCLs) are legally enforceable standards established under the Safe Drinking Water Act to protect public health by limiting the levels of contaminants in public drinking water systems. The MCL is the amount of an analyte (substance) that can be present in a water sample that the government considers acceptable to drink. EPA considers the MCLs when evaluating results from residential drinking water wells.

EPA Secondary MCLs - secondary MCLs are non-enforceable standards regulating contaminants that may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water. EPA recommends secondary standards to public water systems, but does not require systems to comply. However, states may choose to adopt them as enforceable standards.

DEP MCLs (Primary and Secondary) – Chapter 109, Pennsylvania Safe Drinking Water Regulations, defines MCL as the maximum permissible level of a contaminant in water which is delivered to a user of a public water system, and includes the primary and secondary MCLs established under the Federal Safe Drinking Water Act, and MCLs adopted under the act.

U – Indicates that the analyte was not detected. If there is a number next to the U, this number is the amount of analyte that would have to be present to be detected by the lab given the particular method and/or instrumentation.

J – This means that the analyte was detected, but the value of the result is an estimate.

J+ - The result is an estimated quantity, but the result may be biased high.