



P001-BA-012-01
Asbestos: ND

BA-012

BA-011

P001-BA-011-01
Asbestos: ND

BA-014

P001-BA-014-01
Asbestos: 5.4% (Chrysotile)

BA-013

P001-BA-013-01
Asbestos: 19.10% (Chrysotile)




SCALE

1:244

LEGEND

Bulk Sample Location

August 2015 Bulk Sample Location



Notes:
1.) All results presented in percent (%).
2.) ND - None Detected

Figure 5: Bulk Sample Analytical Results Map (East Wing, Basement)

Old Saratoga Hospital Site
Providence Township, New York

UNITED STATES ENVIRONMENTAL
PROTECTION AGENCY
REMOVAL SUPPORT TEAM 3
CONTRACT # EP-S2-14-01

Weston Solutions, Inc.

In Association With Scientific and
Environmental Associates, Inc.;
Environmental Compliance Consultants, Inc.;
Avatar Environmental, LLC; On-Site Environmental,
Inc.; and Sovereign Consulting, Inc

GIS ANALYST:	T. BENTON
EPA OSC:	K. LUCARINO
RST 3 SPM:	K. GUERRERO
FILENAME:	151009_EastBasement.mxd
FIGURE	5
REVISION	0
DATE MODIFIED	10/09/2015



0.002 0.001 0 0.002 0.004 0.006 0.008 Miles